



GRAMS: "HYCOC BANK"

E-Mail: [hyd\\_dccb@yaho.co.in](mailto:hyd_dccb@yaho.co.in)

## THE HYDERABAD (RR) DISTRICT CO-OP. CENTRAL BANK LTD.

Estd.: 20.12.1957

(Andhra Pradesh State Govt. Partnered Bank)

R.No.: 21603

Head Office, Station Road, Nampally, HYDERABAD - 500 001.

Phone Nos.: 6675 8303/04/05/06/08/09 & 6675 6508; Fax No.: 6675 8304/6682 3910.

Ref : Premises/tender/UPS/20-21

Dated:04.05.2021

### **SHORT CHIT TENDER NOTICE**

Quotations are invited for Procurement of UPS with batteries.

The Hyderabad district cooperative central bank ltd., invites tenders for procurement of UPS with batteries of 25 units at our branches as per the specifications provided by the bank through the encrypted mail format as initiated because of the COVID 19 pandemic.

<b>Sno</b>	<b>Description</b>	<b>No of Units</b>	<b>Estimation cost</b>
1	3KVA UPS, 12V/65AH Exide/Quanta SMF 8 Batteries and Battery Stand & Accessories	<b>25</b>	<b>17,50,000.00</b>

- For more details log onto [www.hyderabaddccb.org](http://www.hyderabaddccb.org)
- To participate please send the Quotation/bid by encrypted mail (OTP based) to [premises.hyd@hyddccb.org](mailto:premises.hyd@hyddccb.org) with validity of 1 month.
- Video conference link will be sent to the composer's mail at the time of the tender opening.
- Starting date for submission of tenders is 05.05.2021, time 12.00 Noon.
- Last date for submission of tenders is 11.05.2021 time: 05.00 PM.
- Tenders Opening date: 12.05.2021, Time: 01.00 PM. Tender opening will be done through the OTP verification of composer's contact number.
- Bank has right to cancel or postpone tender process at any point of time.
- **Terms and conditions apply**

**Sd/-**  
**Chief Executive officer**



GRAMS: "HYCOB BANK"

E-Mail: [hyd\\_dccb@yaho.co.in](mailto:hyd_dccb@yaho.co.in)

**THE HYDERABAD (RR) DISTRICT CO-OP. CENTRAL BANK LTD.**

Estd.: 20.12.1957 (Andhra Pradesh State Govt. Partnered Bank) R.No.: 21603

Head Office, Station Road, Nampally, HYDERABAD - 500 001.

Phone Nos.: 6675 8303/04/05/06/08/09 & 6675 6508; Fax No.: 6675 8304/6682 3910.

## **1. Technical Parameters for installation of Batteries and UPS :**

1. Non refundable amount/Participation fee of **Rs: 2,500.00** (CEO HDCCB) payable by bidders in Participation. (we only allow HDCCB's Bankers cheques )
2. EMD for the Installation of batteries & UPS in favor of Hyderabad District Cooperative Central Bank Ltd., payable at our HDCCB branches (2%) i.e., Rs 35,000/- after finalization of tender to the bidder.
3. Detailed Specifications to be mentioned as per the check list uploaded in the website([www.hyderabaddccb.org](http://www.hyderabaddccb.org))
4. Schedule of requirements and hand over time to be submitted to the head office with approximate estimated dates.
5. All the uploaded documents in the website are to be filled and attached to the encrypted mail.
6. Terms and conditions apply.

Sd/-


**Chief Executive officer**

<b>2.Technical Specifications of 3KVA</b>		<b>Check List</b>
<b>MODEL</b>		
PHASE	1 Phase In / 1 Phase Out	
CAPACITY (KVA)	3	
<b>INPUT</b>		
Nominal Voltage	220V / 230V / 240V AC (1Ph+N+PE)	
Voltage Range	110V~300V AC Load Dependent	
Frequency Range	50~60Hz ± 20% (Auto Sensing)	
<b>OUTPUT</b>		
Output Voltage	220V / 230V / 240V AC (L+N)	
AC Voltage Regulation	± 1%	
Frequency Range	Auto Sensing 50 / 60 Hz ± 1~10% Sync Mode (Configurable), 50 / 60 Hz ±0.1Hz Battery Mode	
Crest Factor / Power Factor	3:1 (max.) / 0.8 Standard, 0.9 / 1.0 (Optional)	
Harmonic Distortion	≤ 2 % THD (Linear Load); ≤ 5 % THD (Non-linear Load)	
Transfer Time	Zero	
Waveform	Pure Sine wave	
Over Load	≤ 125% for 10 min., ≤ 150% for 1 min., ≥ 150% for 200 ms	
Efficiency	Up to 90% Dual Conversion Mode	
<b>BATTERY CHARGER</b>		
Nominal Voltage	96	
Battery Quantity	8	
Typical Recharge Time	8 hours to 90% capacity	
<b>SYSTEM FEATURES</b>		
Transfer Time	Zero	
IP Protection	IP 20	
Alarm / Protection	Short Circuit, Input Under/Over Voltage, Over Temperature, Over Current, Over Load, DC Bus Under/Over Voltage and Battery Low	
LED / LCD Display	UPS status, Load % / VA / W, Battery level, Input/Output voltage, Discharge timer, and Fault Code	
<b>STANDARDS</b>		
Quality	ISO 9001, ISO 14001	
Safety	IEC/EN62040-1	
EMC/ Performance	IEC/EN62040-2; IEC/EN62040-3, Complying to CE	
<b>ENVIRONMENT</b>		
Temperature	Operating: 0 ~ 45°C, Storage: -10 ~ 55°C	
Humidity / Altitude	0-95% RH Non-condensing / <1500 m	
Noise	Low Audible Noise Level	
<b>COMMUNICATION</b>		
Standard	RS-232	
*Specifications are subject to change without prior notice.		
Checklist to be uploaded in the mail attachments as per the bidder specifications mentioned in the check list		

### 3. Quotation column.

S.NO	Particulars	Qty	Rate/Unit	Amount	GST(%)	GST Amount	Sub Total
1	3KVA UPS	1					
2	Batteries /	8					
<b>Grand Total</b>							
1. Quotation Excel sheet to be uploaded in the Gmail with encrypted OTP linked with the composers contact number							
2. Upload the quotation in the firms letterhead includes GST.							
3. Must provide minimum warranty of 3 Years for UPS & Batteries respectively.							

#### **4. How to send encrypted mails through GMAIL:**

1. On your computer, go to [Gmail](#).
2. Click Compose.
3. **In the bottom right of the window, click Turn on confidential mode**  .

Tip: If you've already turned on confidential mode for an email, go to the bottom of the email, then click Edit.

4. Set an expiration date(1 Month) and passcode(SMS). These settings impact both the message text and any attachments.
  - If you choose "No SMS passcode," recipients using the Gmail app will be able to open it directly. Recipients who don't use Gmail will get emailed a passcode.

**If you choose "SMS passcode," recipients will get a passcode by text message.**

**Make sure you enter the Composer's phone number, not recipients.**

**Encrypted mails should send @: premises.hyd@hyddccb.org**

**\*\*\*E-mail encryption is mandatory\*\*\***